

ANALYSERAPPORT
16338/12

 Skov Hastrup Vandværk
 Skovhastrupvej 20
 4330 Hvalsø
 Sanne Solmer-Hansen

 Udskrevet: 15-03-2012
 Version: 1
 Udtaget: 01-03-2012 10.10
 Modtaget: 01-03-2012
 Påbegyndt: 01-03-2012
 Udtaget af: Lab./JBE

Drikkevand
Sagsnummer: Skov Hastrup Vandværk
Kunde: Skov Hastrup Vandværk, Skovhastrupvej 23, Skov Hastrup, 4330 Hvalsø

Prøvested: Skov Hastrup Vandværk, Skov Hastrupvej 22, 4330 Hvalsø
 Afgang værk

Prøvetype: Organiske mikroforureninger,

RESULTATER FOR PRØVE 16338/12

Parameter	Resultat	Enhed	Metode	Grænseværdi	Afgang værk
Purge & Trap, drikkevand	i.p.	-	GC/MS, P&T, AK152		
Benzen	<0.020	µg/l	GC/MS, P&T, AK152	1	
Toluen	<0.020	µg/l	GC/MS, P&T, AK152		
Ethylbenzen	<0.020	µg/l	GC/MS, P&T, AK152		
Xylener	<0.020	µg/l	GC/MS, P&T, AK152		
Naphtalen	<0.020	µg/l	GC/MS, P&T, AK152	2	
Trichlormethan (Chloroform)	<0.020	µg/l	GC/MS, P&T, AK152	1	
1,1,1-trichlorethan	<0.020	µg/l	GC/MS, P&T, AK152	1	
Tetrachlormethan	<0.020	µg/l	GC/MS, P&T, AK152		
Trichlorethylen	<0.020	µg/l	GC/MS, P&T, AK152	1	
Tetrachlorethylen	<0.020	µg/l	GC/MS, P&T, AK152	1	
1,2-dichlorethan	<0.020	µg/l	GC/MS, P&T, AK152	1	
2,4-dichlorphenol	<0.010	µg/l	GC/MS AK158	0.1	I
2,6-dichlorphenol	<0.010	µg/l	GC/MS AK158		
Pesticider, Drikkevand grundpakke	påvist	-	GC/LC/MS		
Mechlorprop(MCPP)	<0.010	µg/l	LC/MS/SIM AK: 78		
MCPA	<0.010	µg/l	LC/MS/SIM AK: 78		
Dichlorprop(2,4-DP)	<0.010	µg/l	LC/MS/SIM AK: 78		
2,4-D	<0.010	µg/l	LC/MS/SIM AK: 78		
Simazin	<0.010	µg/l	LC/MS/SIM AK: 78	0.1	
Atrazin	<0.010	µg/l	LC/MS/SIM AK: 78	0.1	
Dichlobenil	<0.010	µg/l	GC/MS/SIM AK: 78	0.1	
4-Chlorprop (4-CPP)	<0.010	µg/l	LC/MS/SIM AK: 78		
2,6-Dichlorprop (2,6-DCCPP)	<0.010	µg/l	LC/MS/SIM AK: 78		
Desisopropylatrazin	<0.010	µg/l	LC/MS/SIM AK: 78	0.1	
Desethylatrazin	<0.010	µg/l	LC/MS/SIM AK: 78	0.1	
Hydroxyatrazin	<0.010	µg/l	LC/MS/SIM AK: 78	0.1	
2,6-Dichlorbenzamid (BAM)	0.075	µg/l	LC/MS/SIM AK: 78	0.1	
Bentazon	<0.010	µg/l	LC/MS/SIM AK: 78	0.1	
Hexazinon	<0.010	µg/l	LC/MS/SIM AK: 78	0.1	
ETU (Ethylthiourea)	#	<0.010	µg/l	LC/MS/SIM AK: 78	
Aminomethylphosphorsyre, AMPA		<0.010	µg/l	LC/MS/SIM AK144	
Desethyl-desisopropylatrazin	#	<0.010	µg/l	LC/MS/MS AK189	
Desethyl-hydroxy-atrazin	#	<0.010	µg/l	LC/MS/MS AK189	
Desisopropyl-hydroxy-atrazin	#	<0.010	µg/l	LC/MS/MS AK189	
2,6-dichlorbenzoesyre	#	<0.010	µg/l	LC/MS/MS AK189	
Didealkyl-hydroxy-atrazin	#	<0.010	µg/l	LC/MS/MS AK189	
Desethylterbutylazin		<0.010	µg/l	LC/MS/SIM AK: 78	0.1
Glyphosat		<0.010	µg/l	LC/MS/SIM AK144	
Hydroxysimazin		<0.010	µg/l	LC/MS/SIM AK: 78	0.1
4-nitrophenol		0.012	µg/l	LC/MS/SIM AK:78	

KOMMENTARER

Højest tilladelige værdi er overholdt for de undersøgte parametre.



Mikkel West-Nørager

Kopi sendt til:

Lejre Kommune Teknisk Forvaltning, Møllebjergvej 4, 4330 Hvalsø
Sundhedsstyrelsen, Rolighed 7,2, 4180 Sorø